

	<b>Heat Pump KEYMARK</b>	
<b>Annex D2</b> 012-024		Rev.-No.: 1 Date: 2016-12-20 Page: 1 of 1

Picture of certificate with main contents

<b>Certificate holder</b>	<b>ATLANTIC GROUP</b> <b>Rue des Fondeurs, BP64</b> <b>59660 Merville, France</b>
<b>Production sites</b>	59660 Merville France and 20230 Chonburi Thailand
<b>Product</b>	Heat Pumps
<b>Product Type</b>	Air/Water
<b>Sub type and Models</b>	Alféa Hybrid Duo Gaz Tri 16, Alféa Condensol Hybrid Duo Gaz Tri 16
<b>Testing basis</b>	EN 14511:2013-12 EN 14825:2013-12 EN 12102:2013-10 KEYMARK Certification Scheme for Heat Pumps (2015-06)
<b>Mark of conformity</b>	
<b>Registration No.</b>	012-024
<b>Right of use</b>	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.  See annex D1 for detailed information.
<b>Validity</b>	<b>2026-12-19</b> <b>To check the validity of this certificate, please visit</b> <a href="http://www.sp.se">www.sp.se</a>

	<b>Heat Pump KEYMARK</b>	
<b>Annex D1</b> 012-024		Rev.-No.: 1 Date: 2016-12-20 Page: 1 of 4

**1. AIR/WATER HEAT PUMPS**

**2**

<b>Certificate data</b>	
Certificate holder name	ATLANTIC GROUP
Address	rue des fondeurs 59660 Merville FRANCE
Type of heat pump	AIR/WATER
Reg. No.	012-024
Certification Body	SP Certifiering
Name of testing laboratory	SP Energy and Bioeconomy



## Heat Pump KEYMARK

Annex D1  
012-024

Rev.-No.: 1  
Date: 2016-12-20  
Page: 2 of 4

### 1. Air/Water heat pumps

	Alféa Hybrid Duo Gaz Tri I6	Alféa Condensol Hybrid Duo Gaz Tri I6
<b>General data</b>		
Refrigerant	R410A	
Mass of refrigerant [kg]	2.5	
GWP EN 517/2014 (kg equivalents CO <sub>2</sub> )	2087	
Frequency [Hz]	50	
Voltage [V]	230	
<b>Test points EN 14511-2 Air/Water heat pump</b>		
<b>A7/W35</b>		
heat output [kW]	15.17	
El input [kW]	3.70	
COP	4.10	
<b>A7/W55</b>		
heat output [kW]	12.24	
El input [kW]	4.93	
COP	2.48	
<b>Test points EN 14511-4</b>		
operating Range A20/W17 lower limit-lower limit (min)		
Please state if the requirement is passed or failed	Passed	
operating Range A35/W55 upper limit- upper limit (min)		
Please state if the requirement is passed or failed	Passed	
Shutting off the heat transfer medium flow		
Please state if the requirement is passed or failed	Passed	
Complete power supply failure		
Please state if the requirement is passed or failed	Passed	
Defrost test only for AirT Water heat pumps		
Please state if the requirement is passed or failed	Passed	




## Heat Pump KEYMARK

Annex D1  
012-024

Rev.-No.: 1  
Date: 2016-12-20  
Page: 3 of 4

<b>Average Climate Low temperature application</b>	
Declared values EN 14825	
$T_{biv}$ [°C]	
heat output [kW]	15.17
El input [kW]	3.70
COP	4.10
Sound power level according EN 12102	
Sound power level indoor [dB(A)]	46
Sound power level outdoor [dB(A)]	70
Declared data regarding ErP regulation	
$\eta_s$	149
$P_{rated}$ [kW]	14
SCOP	3.80
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$	
Pdh: $T_j = -7$ °C [kW]	12.0
COPd: $T_j = -7$ °C	2.4
Pdh: $T_j = +2$ °C [kW]	7.3
COPd: $T_j = +2$ °C	3.6
Pdh: $T_j = +7$ °C [kW]	6.3
COPd: $T_j = +7$ °C	5.5
Pdh: $T_j = +12$ °C [kW]	7.4
COPd: $T_j = +12$ °C	7.2
Pdh: $T_j =$ bivalent temperature [kW]	12.0
COPd: $T_j =$ bivalent temperature [kW]	2.4
Pdh: $T_j = TOL$ [kW]	11.7
COPd: $T_j = TOL$	2.3
$T_{biv}$ [°C]	-7
TOL [°C]	-10
WTOL [°C]	80
Annual energy consumption $Q_{HE}$ [kWh]	7408
$P_{OFF}$ [W]	14
$P_{TO}$ [W]	88
$P_{SB}$ [W]	17
$P_{CK}$ [W]	0
$P_{SUP}$ [kW]	1.9
Type of energy input	Gas

	<b>Heat Pump KEYMARK</b>	
Annex D1 012-024		Rev.-No.: 1 Date: 2016-12-20 Page: 4 of 4

Average Climate Medium temperature application		
Declared values EN 14825		
$T_{biv}$ [°C]		
heat output [kW]		12.24
El input [kW]		4.93
COP		2.48
Sound power level according EN 12102		
Sound power level indoor [dB(A)]		46
Sound power level outdoor [dB(A)]		70
Declared data regarding ErP regulation		
$\eta_s$		117
$P_{rated}$ [kW]		13
SCOP		3.00
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
Pdh: $T_j = -7$ °C [kW]		11.5
COPd: $T_j = -7$ °C		1.8
Pdh: $T_j = +2$ °C [kW]		7.0
COPd: $T_j = +2$ °C		2.9
Pdh: $T_j = +7$ °C [kW]		5.8
COPd: $T_j = +7$ °C		4.1
Pdh: $T_j = +12$ °C [kW]		7.1
COPd: $T_j = +12$ °C		5.5
Pdh: $T_j =$ bivalent temperature [kW]		11.5
COPd: $T_j =$ bivalent temperature [kW]		1.8
Pdh: $T_j = TOL$ [kW]		10.3
COPd: $T_j = TOL$		1.6
$T_{biv}$ [°C]		-7
TOL [°C]		-10
WTOL [°C]		80
Annual energy consumption $Q_{HE}$ [kWh]		9062
$P_{OFF}$ [W]		14
$P_{TO}$ [W]		32
$P_{SB}$ [W]		17
$P_{CK}$ [W]		0
$P_{SUP}$ [kW]		2.7
Type of energy input		Gas